

**ANNEXURE 8.1.2**

**Plant Load Factor of Thermal Power Plants**

**1999-2000**

Sl. No.	SEB/Organisation	Target	Achievement
<b>State Sector</b>			
1	D.V.B.	43.60	50.00
2	H.P.G.C.	48.20	53.10
3	R.S.E.B.	77.60	82.80
4	P.S.E.B.	68.40	74.80
5	UPRVUNL	55.20	49.60
6	G.E.B.	67.60	63.40
7	GSECL	70.50	74.20
8	M.S.E.B.	71.10	71.70
9	M.P.E.B.	66.60	69.30
10	APGENCO	80.00	83.10
11	T.N.E.B.	67.80	72.30
12	K.P.C	82.00	82.00
13	B.S.E.B.	23.60	19.70
14	TENUGHAT V	40.70	31.40
15	O.P.G.C.	54.20	85.60
16	W.B.S.E.B.	36.60	39.90
17	WB.P.DEV.CORP	52.40	56.00
18	D.P.L.	20.40	24.80
19	A.S.E.B.	20.60	17.90
	Average : SEB's	62.70	63.70
<b>Central Sector</b>			
1	Badarpur	69.40	81.20
2	NTPC	69.30	79.50
3	Neyveli	73.40	73.30
4	D.V.C.	36.10	35.80
	Average : Central Sector	66.10	73.60
<b>Private Sector (Utilities)</b>			
1.	A.E.Co/Sabarmati	74.50	82.00
2.	Trombay (TATA)	56.20	60.70
3.	CESC / Titagarh	54.60	64.10
4.	BSES Co.	82.00	86.00
	Average : Private Utilities)	62.20	68.90
	Average : ALL INDIA	63.80	67.30